



HY-TEN GABION SOLUTIONS  
Dunstall Hill Trading Estate,  
Gorsebrook Road, Wolverhampton, WV6 0PJ  
Tel 01902 712200 Fax 01902 714096  
e-mail sales@hy-tengabions.com  
web www.hy-tengabions.com

## **PVC mesh 3.0-3.5mm 50.8x50.8mm**

### **Gabions shall comply with the following specifications**

MANUFACTURE	<p>Gabions shall be manufactured from steel wire formed into a bi-axial mesh grid by electrically welding the cross wires at every intersection.</p> <p>Gabions:-to be factory assembled with stainless steel clips connecting side panels and diaphragms to the base panel.</p>
MESH SIZE	<p>Mesh openings shall be square of nominal dimension of 50.8mm on the grid.</p>
MESH WIRE	<p>Nominal wire diameter shall be 3.0mm to BS 1052</p>
CORROSION PROTECTION	<p>Wire shall be galvanised to BSEN 10244-2;2001 and additionally coated with fusion bonded Green PVC after welding nominally 0.25mm radial thickness.</p>
JOINTING	<p>Gabions shall be provided with lacing wire for site assembly. Lacing wire shall be of nominal wire diameter 2.2mm with an extruded PVC coating of nominal thickness 0.5mm for final jointing.</p>
ROCKFILL	<p>Gabion fill shall be a hard durable and non frost susceptible (rock or stone type) having a minimum dimension not less than the mesh opening and a maximum dimension of 200mm.</p>
CONSTRUCTION	<p>All rockfill shall be packed tightly to minimize voids and the rockfill on the exposed face of the gabion is to be hand packed.</p> <p>Internal windlass bracing ties 2 per 1sqm at 1/3rd points vertically and mid point horizontally on 1m deep units and at mid height at mid point horizontally on 0.5m deep units.</p> <p>Adjacent units to be jointed by continuous lacing on vertical and to the horizontal joints at front and rear of coursing joints.</p> <p>Units shall be filled such that the mesh lid bears onto the rock fill. The lid shall be wired down on all joints and across the diaphragms.</p>